



**REGIONAL DISTRICT OF OKANAGAN-SIMILKAMEEN**  
**REQUEST FOR QUOTATIONS / EXPRESSIONS OF INTEREST**  
**SUN VALLEY WATER SYSTEM**  
**PUMP REPLACEMENT AND UPGRADES**

February 2, 2018

---

**ADDENDUM NO. 2**

By this Addendum # 2, the Request for Quotations document for the above noted Project shall be amended as specified below. This Addendum is being issued in response to the following questions submitted to the RDOS:

- 1. Could contractors be given an approximate budget for the works to aide with design?**
  - The budget for the works is approximately \$100,000.
- 2. Based on the specified equipment requested, having the smallest pump be a 25hp which would only run at a slow speed throughout the winter would not be very efficient and cause unnecessary ware. Is the RDOS open to reusing the 7.5hp pump for winter operations?**
  - The RDOS would be open to reusing the 7.5hp for increased pumping efficiency. Please feel free to include the 7.5hp pump in your design if you see fit. We would want to see the pump integrated with a VFD if the pump is reused.

End of Document