



**REGIONAL DISTRICT OF OKANAGAN SIMILKAMEEN  
INVITATION TO TENDER  
WILLOWBROOK WATER SYSTEM PHASE 1 UPGRADES  
RDOS CONTRACT: RDOS-18-07  
September 10, 2018**

---

**ADDENDUM NO. 1**

By this Addendum#1, the Request for tender document for the above noted Project shall be amended as specified below. The addendum is being issued to update information in the tender document.

---

**Updates to the email and phone numbers:**

- The existing phone number, fax number and the email addresses on the front page for 'Invitation to Tender' stands corrected to  
Phone No: 250-492-0237  
Fax: 250-492-0063  
Email: [info@rdos.bc.ca](mailto:info@rdos.bc.ca)
- Section 00100 'Advertisement for Bids' 'Page 1' quote 'Regional District of Okanagan Similkameen will receive bids for this project before 2:00:00pm on September 18, 2018 Year]' stands corrected to 'Regional District of Okanagan Similkameen will receive bids for this project before 2:00:00pm on September 18, 2018'
- Section 00310 'Available Project Information' subsection 1.3 quote 'This drawing would be made available to interested bidders via email request to Shane Fenske, [sfensek@rdos.ca](mailto:sfensek@rdos.ca)' the email stands corrected at [sfenske@rdos.bc.ca](mailto:sfenske@rdos.bc.ca) .
- The structural drawings markups to provide the details for the footing of the new building is attached with the addendum.
- The general overall site plan includes the right of way and the setbacks to the neighboring building.
- Mechanical Drawing M002 presents a 100mm butterfly valve marked as '1'. The valve shall be Pratt 2FII AWWA Butterfly Valve or Approved equivalent.
- The specification for lighting for the building shall be Metalux VT2 4' industrial high output lamps or Approved equivalent.
- Enclosures
  - Structural Drawings with amendment to Water Treatment Building Sections (S003)- Revision 2
  - General Overall Site Plan- Revision 2

- General Demolition Plan- Revision 2

---

Signature of Bidder

Note: Bidders shall indicate the acknowledgement of the receipt of all the addendums in the bid form.