



REGIONAL DISTRICT OF OKANAGAN-SIMILAMEEN

INVITATION TO TENDER

Okanagan Falls Constructed Wetland

RDOS-19-PW-09

June 10, 2019

ADDENDUM NO. 5

1. QUESTIONS

- a. **Item 1.5.3 – Concrete Head Wall Structures – c/w Handrail & gate: What is the design/spec for the headwall? What is the design/spec for the handrail? What is the design for the hinged grate?**

Please assume a Kon Kast “medium” headwall (1491) structure (or approved equal) to accommodate 726 mm OD pipe. Accompanying hinged grate (1491HG) and handrail to match (hot dipped galvanized).

- b. **Item 1.8.2 – 400 gate valve. 1.8.10 you have force main tie-ins 200mm onto 400mm and one for 200mm onto 200mm. You don’t show a force main tie-in for the 400mm in line valve. Would you like us to use 1.8.2 as a complete install?**

Yes. Please quote the in-line valve as a complete install.

- c. **Can the existing barbed wire be reused to tie back into the new gate system? Because the drawings do not show where new/old fencing is to stop and or start?**

As long as it is in good condition, it’s fine to reuse the existing wire and tie back into the gate system.

END OF DOCUMENT