



## REGIONAL DISTRICT OF OKANAGAN-SIMILAMEEN

### INVITATION TO TENDER

#### Okanagan Falls Constructed Wetland

RDOS-19-PW-09

June 11, 2019

#### ADDENDUM NO. 6

---

##### 1. REVISIONS

- a. Sheet 6 of 18 of the tender plans (INLET PIPE CONNECTION DETAILS) requires the following gradation for riprap:

*100% FINER THAN 300*

*50% FINER THAN 200*

*0% FINER THAN 100*

##### 2. QUESTIONS

- a. **The Rhino Skin for the Sand Filter, what thickness of Rhino Skin s required – 20mm, 30mm, or 40mm?**

20 mm thickness is required.

- b. **SP16 – Full Depth Reclamation. Can you elaborate on what exactly this is? What is the expectation for restoration?**

Under SP16, the term “full depth reclamation” was used in error. For this item, the expectation is simply that the contractor provide a lump sum cost to restore the existing asphalt surface to a condition that is equal (or better) than existing.

END OF DOCUMENT